

有害物質項目（流入水）

採水月日 項 目	単位	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年間 平均	最小 表示値
		3日	8日	5日	3日	7月31日	4日	2日	6日	4日	9日	5日	3日		
カドミウム及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
シアン化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
有機燐化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
鉛及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
六価クロム化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.02
砒素及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
水銀及びアルキル水銀その他の水銀化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
アルキル水銀化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
ポリ塩化ビフェニル	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
トリクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
テトラクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
ジクロロメタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
四塩化炭素	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 2-ジクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 1-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
シス-1, 2-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
1, 1, 1-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
1, 1, 2-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 3-ジクロロプロペン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 4-ジオキサン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.05
チウラム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006
シマジン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
チオベンカルブ	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.02
ベンゼン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
セレン及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
アンモニア、アンモニウム化合物、亜硝酸化合物及び硝酸化合物	mg/L	7.6	5.6	6.4	4.4	6.8	4.8	7.6	6.8	8.0	9.2	7.6	11	7.1	0.01
ふっ素及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	0.1	ND	ND	0.1	0.1	ND	0.1
ほう素及びその化合物	mg/L	0.03	0.02	0.03	0.02	0.02	0.03	0.03	0.03	0.04	0.04	0.04	0.03	0.03	0.02
ダイオキシン類	pg-TEQ/L	—	—	—	—	—	—	—	1.5	—	—	—	—	1.5	—
PFOS及びPFOA	ng/L	10	—	—	—	—	—	11	—	—	—	—	—	11	0.3

* ND : 最小表示値未満

有害物質項目（放流水）

採水月日 項 目	単位	4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年間 平均	最小 表示値
		3日	8日	5日	3日	7月31日	4日	2日	6日	4日	9日	5日	3日		
カドミウム及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
シアン化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
有機燐化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
鉛及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
六価クロム化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.02
砒素及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
水銀及びアルキル水銀その他の水銀化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
アルキル水銀化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
ポリ塩化ビフェニル	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.0005
トリクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
テトラクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
ジクロロメタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
四塩化炭素	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 2-ジクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 1-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
シス-1, 2-ジクロロエチレン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
1, 1, 1-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
1, 1, 2-トリクロロエタン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 3-ジクロロプロペン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.001
1, 4-ジオキサン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.05
チウラム	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.006
シマジン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.003
チオベンカルブ	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.02
ベンゼン	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
セレン及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.01
アンモニア、アンモニウム化合物、亜硝酸化合物及び硝酸化合物	mg/L	5.2	6.0	5.1	3.2	5.0	4.0	6.1	6.1	6.1	5.7	6.2	7.0	5.5	0.01
ふっ素及びその化合物	mg/L	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	0.1
ほう素及びその化合物	mg/L	0.03	0.02	0.03	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.03	0.02
ダイオキシン類	pg-TEQ/L	—	—	—	—	—	—	—	0	—	—	—	—	0	—
PFOS及びPFOA	ng/L	7.5	—	—	—	—	—	9.6	—	—	—	—	—	8.6	0.3

* ND : 最小表示値未満